



- NOTES:**
1. ALL PRIMARY AND SECONDARY DUCTS SHALL BE 4" PVC UNLESS SPECIFIED OTHERWISE.
 2. INSTALL DUCTS WITH 36" MIN. COVERAGE AND TRENCH MUST BE INSPECTED BY E.U. PRIOR TO BACKFILLING.
 3. FULL SIZE TEMPLATE AVAILABLE UPON REQUEST FROM E.U. ELECTRICAL DEPT.
 4. 6-4" SECONDARY DUCTS MAXIMUM.

APPROVAL	REVISED	3 Ø TRANSFORMER PAD 75 - 1000 KVA (SUPPLIED BY EU)
<i>Talbot W Bane</i> 4/25/06 EU MANAGER OF ENGINEERING DATE		
ISSUED 12/14/04		STANDARD No. E-3.01