



Notes:

1. Proposed Conduits Are To Extend 2' Beyond Back Of Sidewalk.
2. Adjust Location Of Proposed Conduits As Necessary To Avoid Conflicts With Proposed And Existing Utilities.
3. Road Crossings To Be Marked With A 2x4 At Each End. Gas Duct To Be Marked Separate From Duct Bank.
4. Ducts To Have A Minimum Depth Of 36". If Ducts Conflict With Other Utilities And Have A Depth Greater Than 48", Provisions Have To Be Made So Ends Of Ducts Are No Greater Than 48" Deep.

APPROVAL	REVISED	<p style="text-align: center;">TOWN OF EASTON AND EASTON UTILITIES COMMISSION STANDARD DETAILS TYPICAL/INTERSECTION DUCT BANK INSTALLATION</p>
 EU MANAGER OF ENGINEERING DATE		
ISSUED: MAR 24, 2006		