



ELECTRIC NOTES

1. 200A electric meter (Typical).

GAS NOTES

1. Gas meter locations shall be agreed upon by the customer and Easton Utilities in advance of construction and are subject to final approval by Easton Utilities.
2. Gas metering assemblies will not be installed in places where it may be subject to damage.
3. Should Easton Utilities determine bollards are required to protect its meter assemblies, the customer shall be required to provide such protection at their cost.
4. Outside gas meter assemblies are recommended to be at least three (3) feet from any equipment with an open flame or subject to electrical arcing.
5. Refer to National Fuel Gas Code 2002, Easton Utilities Gas Service Tariff and Customer Handbook for additional requirements.

<p>APPROVAL</p> <p><i>Talbot Wilson</i> 4/10/07 EU MANAGER OF ENGINEERING DATE</p>	<p>REVISED</p>	<p>TOWN OF EASTON AND EASTON UTILITIES COMMISSION STANDARD DETAILS ELECTRIC METER, GAS METER & CATV BOX LOCATIONS FOR TOWNHOUSES</p>
<p>ISSUED: NOV 1, 2006</p>		<p>STANDARD NO. E-5.00</p>