



NOTES:

1. PROVIDE 4" MIN. TOPSOIL, FERTILIZE, SEED & MULCH ALL DISTURBED AREAS ON BOTH SIDES.
2. PAVING:
 BITUMINOUS CONCRETE (MINIMUM)
 SURFACE COURSE 1.5" 'SF' OR SUPERPAVE 9.5MM
 BASE COURSE 2.5" 'BC' OR SUPERPAVE 19.0MM
3. SUBBASE:
 6" GRADED AGGREGATE COMPACTED TO 95% OF ASTM D1557, MODIFIED PROCTOR METHOD.
4. SUBGRADE:
 COMPACT APPROVED SUBGRADE TO 95% OF ASTMD1557 - CBR TESTING SHALL BE PERFORMED ON THE SUB-GRADE AND APPROVED BY THE TOWN ENGINEER PRIOR TO THE START OF CONSTRUCTION PRIOR TO CONSTRUCTION DOCUMENT APPROVAL.
5. ENTIRE 20' WIDTH SHALL BE CLEARED AND GRADED AS SHOWN.
6. MINIMUM RATE OF GRADE FOR ALLEYS SHALL BE 1.00%.

Y:\0000\CADD STANDARDS\DETAILS\City Details\Easton MD\DETAILS\PW-1.03.dwg Dec 22, 2010 - 1:55pm, (batn)

APPROVAL  TOWN ENGINEER DATE	REVISED	TOWN OF EASTON AND EASTON UTILITIES STANDARD DETAILS RESIDENTIAL ALLEY
	AUG. 1, 94	
	JULY 1, 98	
	SEP 1, 02	
	JAN 1, 07	
	FEB 25, 09	
ISSUED: MARCH 1, 1994	JAN 1, 11	STANDARD NO. PW-1.03