



Notes:

1. Precast Manhole Shall Conform To ASTM C-478-78A As Manufactured By: York Concrete Septic Tanks Inc. York Pa. Or An Approved Equal.
2. Mortar Shall Be "Type S".
3. Bench And Channel Shall Be Brick Or Handformed Concrete. Min. Thickness Of 4", Bench Shall Slope To Top Of Pipe 1/2" Fall Per Foot.
4. Manhole Steps Required Over Effluent Side As Shown.

APPROVAL	REVISED	TOWN OF EASTON AND EASTON UTILITIES STANDARD DETAILS SHALLOW PRECAST MANHOLE
 EU MANAGER OF ENGINEERING DATE	MAY 1, 89	
	AUG 1, 94	
	MAR 9, 95	
	FEB 1, 02	
ISSUED: MAY 1, 1986		STANDARD NO. SS-1.01