


Notes:

1. Add Detector Tape To All Pipe.
2. Use Class 50 Ductile Iron For Services With Less Than 3' Of Cover.
3. Reinforced Coated Tracer Wire As Manufactured By Copperhead Industries, LLC, P.O. Box 1081, Monticello, MN, 55362, Or An Approved Equal.
4. Thoroughly Tape Mechanical Connections With Electrical Tape.

APPROVAL	REVISED	TOWN OF EASTON AND EASTON UTILITIES STANDARD DETAILS DROP SEWER HOUSE CONNECTION
 EU MANAGER OF ENGINEERING DATE	OCT 1, 88	
	MAR 1, 94	
	AUG 1, 94	
	MAR 9, 95	
	SEP 1, 98	
ISSUED: MAY 1, 1986	SEP 1, 09	STANDARD NO. SS-8.01