



Note:

1. All Fittings Shall Be Mechanical Joint, With Ductile Iron Retainer Glands And Mega-Lug Or Equivalent Restraint.
2. Anchoring Tee Shall Be As Indicated And As Manufactured By Griffin Pipe Products, 1100 West Front St. Florance, N.J. 08518, Or An Approved Equal.
3. Retainer Gland Shall Be As Indicated And As Manufactured By Russell Pipe & Foundry Co. Inc., 910 Washington St., Alexander City, AL. 35010, Or An Approved Equal.

APPROVAL	REVISED	TOWN OF EASTON AND EASTON UTILITIES STANDARD DETAILS ANCHORING TEE
<i>Talbot W. Bane</i> 4/25/06 EU MANAGER OF ENGINEERING DATE	AUG 1, 94	
	MAR 9, 95	
	MAR 1, 98	
ISSUED: MAY 1, 1986	STANDARD NO.	W-2.01