



BODY SIZE	3/4"	1"	1-1/4"	1-1/2"	2"
A	14-1/4	14-3/4	20-3/4	21-3/8	23-1/8
B	7-1/4	7-1/4	12-3/8	12-3/8	12-3/8
C	4-5/16	4-5/16	6-1/8	6-1/8	6-1/8
D	1-5/8	1-7/8	2-3/16	2-5/8	3
E	2-7/16	2-7/16	3-13/16	3-13/16	3-13/16
F	5-7/16	5-7/16	6-3/8	6-3/8	6-3/8
G	13/16	13/16	1-3/8	1-3/8	1-3/8
TEST COCKS	1/8x1/4 NPT	1/8x1/4 NPT	1/4x1/4 NPT	1/4x1/4 NPT	1/4x1/4 NPT
NET WT.	8.8	9.5	23.2	25.7	31.5

Notes:

1. Reduced Pressure Backflow Preventer Shall Be Equivalent To Apollo 1015 Or Conbraco, Series 40-100 Or Equal As Approved By Easton Utilities.
2. Assembly To Be Used For Pipe 3/4" To 2".
3. To Be Installed In Horizontal Position With Easy Access For Testing.

APPROVAL	REVISED	TOWN OF EASTON AND EASTON UTILITIES COMMISSION STANDARD DETAILS BACKFLOW PREVENTER DOUBLE CHECK VALVE ASSEMBLY
 EU MANAGER OF ENGINEERING DATE		
ISSUED: SEPT 1, 2008		STANDARD NO. W-5.20